

Material Safety Data Handling

Reference: Material Safety Data Sheets (MSDS) For Lighting Ballasts

Under the Federal Hazard Communication Standard CFR 1910, 1200; ballasts fall into the category of "Article."

"Article" as defined (iii) in the standard means a manufactured item, which does not release, or otherwise result in exposure to a hazardous chemical under normal conditions of use.

Therefore, an MSDS is not required for ballasts or ballast components.

Sincerely,

Universal Lighting Technologies
Technical Engineering Services
1-800-225-5278

Reference: PCBs

Fluorescent and HID ballasts are used in fixtures in commercial, institutional, industrial, residential and specialty markets. One of the components used in all high power factor ballasts is a capacitor. These capacitors, used in ballasts made by every manufacturer in the industry, contained PCBs in small amounts until 1978. At that time, PCBs were outlawed and a change was made to an alternative material.

All high power factor Universal Lighting Technologies Universal® and Triad® ballasts manufactured since January 1979 do not contain PCBs and is indicated on the product label (Normal or low power factor ballasts do not contain capacitors and therefore never contained PCBs).

The EPA (www.epa.gov) has recognized the existence of PCBs in ballasts. We suggest you contact your state EPA office regarding proper disposal in your area.

Sincerely,

Universal Lighting Technologies
Technical Engineering Services
1-800-225-5278



*It's **EASY**
to **REACH US...***

UNIVERSAL LIGHTING TECHNOLOGIES, INC.
51 Century Blvd., Suite 230
Nashville, TN 37214-3683

GENERAL INFO: **(615) 316-5100**

For Technical Engineering Services (TES),
application support and warranty information,
call **1-800-225-5278**

WEBSITE: **unvlt.com**
EMAIL: **webmaster@unvlt.com**

LIT#: LFTS080417